

TOWN OF ANDOVER  
BUILDING AND LAND USE OFFICE

April 13, 2023

William Genovese  
116 Christian Lane  
New Britain, CT 06051

RE: 497 Route 6, Andover  
Gravel Pit Restoration

Per our recent conversation please find below a list of action

- 1) Remove site fence from a point approximately 100' in front of the base of the slope of the "hill" toward the rear of the site so as to remove possible obstacles for wildlife habitat. Leave remaining silt fence in place until requested;
- 2) Provide updated documentation of a performance bond per the original approval (by **4.17. 23**);
- 3) Install plantings per original plan by **April 30, 2023**;
- 4) Seed/hay areas not currently seeded, providing additional topsoil as necessary (also by **April 30, 2023**). Please note that I have a number of concerns regarding the stabilization of the site as proposed. More particularly, topsoil was not spread on a considerable portion of the property and 2) wind conditions were such that a seeding without preventative measures would not adequately stabilize the site. Please have your landscaping contractor provide me with a plan of action so as to insure that seeding the site will in fact stabilize the site. The plan should include the seed variety, method of installation, wind protection and whatever other measures may be needed for stabilization.

Should you have any questions please contact me at 9860.742.4305.

Thank you.

Jim Hallisey  
Zoning Agent

C: Building Administrator