

From: Fire Marshal <firemarshal@andoverct.org>
Sent: Tuesday, June 6, 2023 9:12 PM
To: Anderson, Eric <eanderson@andoverct.org>
Subject: Senior Center

Eric,

I measured the distance from the fire pond on Route 316 to the end of the parking lot at the town hall where the proposed Senior Center is being proposed, it's less than 3/10 of a mile or 1584 feet.

The layout of the SC looks good. Egress door sizes are not provided. Egress doors of 36" should be considered.

There are no mechanical or electrical drawings, in the prints I received. They will be needed for project sign off.

Access to the rear of the Elementary School appears to be adequate. A low or no curb should be considered, in the single handicap parking spot and the access to the garage under the school's gymnasium.

Access to this area will have to be monitored during construction.

A plan review will be performed when the permit for the project is submitted.