

## *Town of Andover*

---

17 SCHOOL ROAD • ANDOVER, CT 06232

To: Planning and Zoning Commission, Town of Andover CT

From: Joseph Wagner, Andover Inland Wetlands and Watercourses Agent

Date: June 19<sup>th</sup>, 2023


Subject: Review of Proposed Andover Community Center

I reviewed the plan for the Andover Community Center dated May 18, 2023, and revised on June 16, 2023.

The proposed changes to the plan include a fueling area, a rain garden, and a tracking pad—all of which are located within the 100-foot Upland Review Area (URA) of a wetland.

These proposed changes/additions to the plan require a wetlands permit application and an agent-issued permit for work within the URA.

As part of my review, I would like to see a description of the spill containment equipment and supplies, and the plan for their intended use in the fueling area.



---

Joseph Wagner

Wetlands Agent, Town of Andover

wetlands@andoverct.org