

PROPOSED SEPTIC SYSTEM REPAIR 10/17/2023
31 LAKESIDE DRIVE, ANDOVER
DOROTHY CARSO - OWNER

* SYSTEM DESIGN IS FOR A 2 BEDROOM

* EXISTING 2 COMPARTMENT SEPTIC TANK
TO REMAIN - EFFLUENT FILTER TO BE ADDED

* MANTIS DW-100 TO BE USED 375 SQ. FT REQ'D
4 UNITS = 4 X 5 L.F. X 20 SQ. FT/L.F. = 400 SQ. FT
EST. MLSS = H.F.(16) X F.F.(1) X P.F.(1) = 16'

* LEACHING SYSTEM TO BE NO MORE THAN
24" INTO GRADE

* MANTIS SYSTEM TO BE INSTALLED BETWEEN
2ND & 3RD ROW OF EXISTING INFILTRATORS.

* EXISTING SYSTEM TO BE ABANDONED IN PLACE

* INSTALLER TO SCHEDULE STAKE/B.M AND
SCARIFICATION INSPECTIONS

* TOWN OF ANDOVER INLAND WETLANDS PERMIT TO
BE SECURED

PLANS/INSTALL: CHRIS MORRELL - EASTERN ENVIRONMENTAL SEPTIC
22 CLUBHOUSE RD, LEBANON CT 06249 CT #006121