

Jim,

This note is confirming our conversation in regards to the 26 Old Farms Road/Pine Ridge Drive subdivision. I see no issues with Fire Department gaining access to the properties if there were to be an emergency. Be mindful that fire apparatus are large pieces of equipment and an overhead clearance of 12-15 feet should be maintained, along with the width requirements of the approved driveway.

Regards,

Michael Lester
Fire Marshal
Town of Andover