

From: Costagliola, Sarah <scostagliola@blcompanies.com>
Sent: Monday, March 21, 2022 2:03 PM
To: Zoning <zoning@andoverct.org>; Fire Marshal <firemarshal@andoverct.org>
Cc: jjarson278@gmail.com; 10ptrbuckmaster@gmail.com; Bruton, Matthew <mbruton@Blcompanies.com>
Subject: RE: Commercial Development Fire Safety Review

Good afternoon,

To answer some of your questions below:

- We are not proposing a fire alarm system. It is not required by CT code as our occupancy is too low.
- We can install a Knox box in a location desired by the Fire Department.

Please let me know if you have any other questions.

Thank you,

Sarah Costagliola (LeClerc), P.E.
Project Engineer II
BL Companies | *Employee owned. Client driven.*



100 Constitution Plaza, 10th Floor, Hartford, CT 06103
tel: 860.249.2200 | direct: 860.760.1916
fax: 860.249.2400
www.blcompanies.com

Please make note of my name change and new email address. My name has been changed from Sarah LeClerc to Sarah Costagliola and my new email is scostagliola@blcompanies.com