

**From:** Michael Lester [mailto:Mlester\_5@hotmail.com]

**Sent:** Monday, April 20, 2020 4:17 PM

**To:** zoning@andoverct.net; zoning@andoverct.org; ronald mike <10ptrbuckmaster@gmail.com>

**Subject:** 353 Lake Road

Jim,

Subject: This afternoons (04/20/2020) meeting, plan review and site walk with: Fire Chief, property owner, site developer, Zoning Agent and Fire Marshal.

Neither Fire Chief Ron Mike or myself see any issues with the driveway plans relating to egress for fire apparatus. The driveway will be common with 351 Lake Road for approximately 100', then continue for another 300' to the home, with a turnaround area.

Mike Lester  
Fire Marshal  
Town of Andover  
(860) 465-6162